

ANNEXURE - C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

Memo No: 1480/4D

Dated: 10/06/2026

It is certified that an inspection team headed by the Assistant Engineer, (Head Quarter), from Public Health Engineering Department (PHED) , Howrah Division inspected the **Doon Techno School, Amta Road, Dakshin Jhapardaha, Domjur, Howrah- 711405** on **04.06.2026** on the basis of Water Test Report (Attached) bearing no : 7150 dated: 09/06/2026 of Public Health Engineering Directorate (PHED Lab).

Certified that **Doon Techno School** has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central State/U.T. Govt.

This certificate is valid till 10.06.2027



Signature with Seal:

NAME : KAUSIK SETH

DESIGNATION :

Name and Address of the office/Department:

[Signature] 10/06/26
Assistant Engineer (H/Q)
Howrah Division,
Public Health Engineering Dto
Govt of W. B.

Note: The Certificate is to be issued by authorized officer/PHED Lab/Local bodies



Results of Chemical Examination

DISTRICT LABORATORY UNDER HOWRAH DIVISION
PUBLIC HEALTH ENGINEERING DIRECTORATE

DATE OF REPORT	09.06.2026
SAMPLE NO.	7150
SAMPLE SOURCE	Drinking Water from Doon Techno School, Amta Road, Dakshin Jhapordaha, Domjur, Howrah.
SAMPLE COLLECTED BY	Biplap Khan (Staff of this school)
DATE OF COLLECTION	08.06.2026
DATE OF TESTING	08.06.2026

SL NO.	Parameters	Expressed As	Recommended Drinking Water Quality as per IS 10500: 2012		RESULT
			Desirable Limit (Max)	Permissible Limit (Max)	
1.	pH	-	6.5 - 8.5	No relaxation	6.55
2.	Turbidity	NTU	1	5	0.70
3.	Total Dissolved Solid	mg/l	500	2000	85
4.	Total Hardness	mg/l	200	600	35
5.	Iron	mg/l	1.0	No relaxation	0.07
6.	Manganese	mg/l	0.1	0.3	0.01
7.	Arsenic	mg/l	0.01	No relaxation	BDL
8.	Salinity	ppt	-	-	0.0
9.	Chloride	Mg/l	250	1000	40.55

N.B.: 1. Sample was not collected by the Department so source and depth not confirmed
2. Statement of Conformity: None (not asked by Customer), hence decision rule is not applicable.

Chemist
Howrah Dist. Lab
PHE Dte.

Asst. Engineer
Howrah Division
PHE Dte.



Results of Bacteriological Examination

DISTRICT LABORATORY UNDER HOWRAH DIVISION
PUBLIC HEALTH ENGINEERING DIRECTORATE

DATE OF REPORT	09.06.2026
SAMPLE NO.	7150
SAMPLE SOURCE	Drinking Water from Doon Techno School, Amta Road, Dakshin Jhapordaha, Domjur, Howrah.
SAMPLE COLLECTED BY	Biplap Khan (Staff of this school)
DATE OF COLLECTION	08.06.2026
PERIOD OF TESTING	08.06.2026-09.06.2026

SL. NO.	PARAMETERS	DESIRABLE LIMIT	RESULT
1	Total Coliforms (CFU/100ml)	Nil	Nil (Not detected)
2	Faecal Coliforms (CFU/100ml)	Nil	Nil (Not detected)

N.B :1. Sample was not collected by the Department so source and depth not confirmed.
2.Statement of Conformity: None (not asked by Customer), hence decision rule is not applicable.

Bacteriologist
Howrah Dist. Lab.
PHE Dte.

Asst. Engineer
Howrah Division
PHE Dte.